

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0075:169 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford CT 06472-1653
Contact: Larry Flood (203) 484-1200

DESIGN: Model MS-5024UD control unit. Local and central station, noncoded, automatic, manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product description and operational considerations. System components:

MS-5024UD	Control Unit
RM-5F	Relay Module
ADM-24	Annunciator Driver
XRM-24	Transformer

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1993 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For *Fire Alarm Verification* feature, the retard/reset/restart must be adjusted to 30 sec. or less.

08-04-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager